



- NOTE:
1. FLOW METERS ARE TO BE INSTALLED CLOSE TO THE PLANT. NO BRANCHES ARE TO BE INSTALLED BETWEEN THE METER AND THE PLANT.
  2. ISOLATION VALVE SHALL BE INSTALLED AS CLOSE TO BUILDING ENTRANCE AS POSSIBLE.
  3. REMOTE MOUNT ELECTRONICS HEAD IF METER IS INSTALLED AT AN ELEVATION MORE THAN 5' ABOVE FINISHED FLOOR.
  4. REFER TO MANUFACTURER'S INSTALLATION MANUAL FOR INSTALLATION INSTRUCTIONS AND ADDITIONAL REQUIREMENTS.
  5. REFER TO UTILITY SPECIFICATIONS FOR ALL PIPE MATERIAL AND INSULATION REQUIREMENTS.

**MULTIPLE UTILITIES PLANT HYDRONIC FLOW METER PIPING DIAGRAM**

NO SCALE MD 336333 004 2025-XX-XX

- DESIGNER NOTES:
1. REVISE DIAGRAM ON A PROJECT BASIS FOR ACCURATE UTILITIES PLANT EQUIPMENT AND BUILDING QUANTITIES.
  2. PLANT AND BUILDING METERS ARE TO BE PROVIDED FOR EACH SYSTEM.